

Hercules Incorporated West 7th Street P.O. Box 1937 Hattiesburg, MS 39401 (601) 545-3450

April 14, 1987

Mr. Earl Mahaffey Bureau of Pollution Control P. O. Box 10385 Jackson, MS 39209

Dear Earl:

Per our previous phone conversation addressing an underground storm drain which the flow enters and exits our property, please find the following information relative to the foam discharge we discussed.

Because of the evidence of foam in this drain, an intensive investigation revealed a small leak (dripping) into this drain from an old abandoned underground industrial sewer line which had been sealed with concrete. The line has been sealed off again and the problem has been corrected.

If I can answer any questions, please let me know.

Very truly yours,

Charles Jordan

Environmental Supervisor

CJ:sj 0800C